

WHAT HAPPENED? WHAT IS BEING DONE?

The action level was exceeded for lead during the most recent round of monitoring of drinking water taps. Sample locations and sample results are available and will be posted via the Consumer Notice of Lead Results.

Noncompliant taps have been removed from service.

We are beginning to take corrective action. This involves additional sampling. Also, we are performing plumbing assessment to determine if fixtures and connecting plumbing should be replaced with new "lead-free" materials, and assessing the option of corrosion control treatment.

For More Information

Call us at: 989-786-2253

For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's Website at www.epa.gov/lead or contact your health care provider.