

Lead and Copper Consumer Notice Drinking Water Sample Results Table

(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent drinking water quality Lead and Copper sample results. Lead and Copper samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

Water System Name : LEWISTON K-6 SCHOOL

WSSN : 2002360

<u>Sample Number</u>	<u>Sample Location</u>	<u>Sample Date</u>	<u>Analyte Code</u>	<u>Results *</u> milligrams / liter	<u>Comment</u>
Samples related to Source # 001					
LJ18042	ROOM 122 HAND SINK	8/11/2020	Lead	0.02	
LJ18042	ROOM 122 HAND SINK	8/11/2020	Copper	0.07	
LJ18048	RM 207 HAND SINK	8/11/2020	Lead	0.001	
LJ18048	RM 207 HAND SINK	8/11/2020	Copper	0.06	
LJ18049	RM 105 HAND SINK	8/11/2020	Lead	0.002	
LJ18049	RM 105 HAND SINK	8/11/2020	Copper	0.05	
LJ18050	RM 121 HAND SINK	8/11/2020	Lead	0.001	
LJ18050	RM 121 HAND SINK	8/11/2020	Copper	0	
Samples related to Source # 002					
LJ18043	RM 136 HAND SINK	8/11/2020	Lead	0.023	
LJ18043	RM 136 HAND SINK	8/11/2020	Copper	0.64	
LJ18044	RM 137 HAND SINK	8/11/2020	Lead	0.017	
LJ18044	RM 137 HAND SINK	8/11/2020	Copper	0.34	
LJ18045	KITCHEN SINK	8/11/2020	Lead	0.011	
LJ18045	KITCHEN SINK	8/11/2020	Copper	0.17	
LJ18046	RM 165 HAND SINK	8/4/2020	Lead	0.003	
LJ18046	RM 165 HAND SINK	8/4/2020	Copper	0.05	
LJ18047	LOWER DF BETWEEN LOCKER RM	8/11/2020	Lead	0.002	
LJ18047	LOWER DF BETWEEN LOCKER RM	8/11/2020	Copper	0.18	

* All Lead and Copper sample results will be reviewed by your local health department to assess compliance with Lead and Copper regulations under the Safe Drinking Water Act, 1976 PA 399, as amended, the U.S. Environmental Protection Agency (U.S. EPA). Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.

For information on the health effects of Lead/Copper, and how to decrease your exposure, call the Safe Drinking Water Information Hotline at +1 (800)-426-4791, visit the U.S. EPA's Web site at www.epa.gov/lead, or contact your health care provider.

Printed: 8/23/2020